

Valves | Water Control Valves (OS&Y and NRS Gate Valves) | **Gate Valves, Inside Screw**

Models 3288-300-FLA, 3288-300-GG, 3288-300-FG, 3288-200-FLA, 3288-200-GG, 3288-200-FG

Product Description

Resilient Seated Gate Valves. 2 through 12 in. NPS. Available with the following end connections and rated working pressures:

Product Specification

Model No	Valve Size		Rated Working Pressure		End Connection
	in	(mm)	psi	(kPa)	
3288-300-FLA	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	300	(2065)	Flange x Flange (ANSI, BS10, EN1092)
3288-300-GG	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	300	(2065)	Groove x Groove
3288-300-FG	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	300	(2065)	Flange (ANSI, BS10, EN1092) x Groove
3288-200-FLA	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	200	(1375)	Flange x Flange (ANSI, BS10, EN1092)
3288-200-GG	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	200	(1375)	Groove x Groove
3288-200-FG	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	200	(1375)	Flange (ANSI, BS10, EN1092) x Groove

Details

Category	Gate Valves, Inside Screw
Class of Work	1130 - OS&Y and NRS Gate Valves
Approval Standard	FM 1120, 1130 - Fire Service Water Control Valves (OS&Y and NRS Type Gate Valves)

Company

Fivalco Ltd
 1301 Bank of America Tower, 12
 Harcourt Road, Central, Hong
 Kong
<http://fivalcovalves.com>

FM Approvals

Certification Type	FM Approved
Listing Country	Hong Kong